

**Call for market consultation No. 53391 on the ‘Supply of excitation current transformer for Thyripart excitation system for Units 5 and 6 5(6)GV(W,X)’**

Kozloduy NPP EAD hereby informs all interested parties that in connection with the preparation for award of a public procurement contract and determination of an estimate value, on the grounds of Art.44 of the Public Procurement Act is collecting indicative proposals for the ‘Supply of excitation current transformer for Thyripart excitation system for Units 5 and 6 5(6)GV(W,X)’.

The proposal should include:

- detailed description of the proposed goods, as specified in the technical specification attached below;
- unit price and total value, VAT excluded;
- information about timeline and terms of delivery, warranty period;
- accompanying documentation upon delivery;
- exact address and contact person, telephone number, fax, e-mail, website.

Inquiries about the market consultations may be made by 08 May 2024 at the following e-mail address: [commercial@npp.bg](mailto:commercial@npp.bg), and the clarifications will be published in the Buyer’s profile.

Deadline for submission of indicative offer: 10 May 2024 at the following e-mail: [commercial@npp.bg](mailto:commercial@npp.bg)

All information exchanged on the occasion of the market consultations will be published in the Buyer's profile.

By submitting an indicative offer, each participant in the market consultations agrees that the proposal and any additional information provided as a result of the market consultations will be made available to the public in the Buyer’s profile.

The Contracting Authority shall be entitled to use the indicative offers received in the course of the conducted market consultations for the award of public procurement up to the value thresholds as specified in Article 20, paragraph 4 of the Public Procurement Act.

Further information may be obtained from Tihomir Angelov, Marketing Expert, tel. +359 973 7 40 14, e-mail: [tangelov@npp.bg](mailto:tangelov@npp.bg)

Enclosures:

1. Technical Specification
2. Indicative offer standard form

### **Technical Specification**

Call for market consultations on the ‘Supply of excitation current transformer for Thyripart excitation system for Units 5 and 6 5(6)GV(W,X)’

Current transformer, model STD115 - 3.6

Procurement code: BV.: 28512

Primary side: 3 x 781 A

Rated voltage of primary side: 3.64 kV.

Coil voltage, maximum: 6.68 V/winding

Frequency: 50 Hz

Coupling group: IIIyn6y6

Secondary side: 1:3 x 45 A

Secondary side: 2:3 x 231 A

Test voltage:

Primary side to secondary side + core: 8.3 kV.

Secondary side to core: 5 kV.

Secondary side to secondary side: 2.5 kV.

Weight: 550 kg

Dimensions; Length x Width x Height in mm: 1100 x 600 x 750

Appendix: Drawing 02-029-BT-28512-M

*Note: The procurement shall include only one current transformer*